



# Hidayatullah National Law University

Nava Raipur, Atal Nagar – 493661 (C.G.)  
Email: registrar@hnl.u.ac.in; Website: www.hnl.u.ac.in  
Contact: 7587017804

No.:HNLU/433/2026

Date: 08.05.2026

## CORRIGENDUM

**Tender No.: HNLU/376/NIT/2025-26**

**Subject: Corrigendum to Tender Document for False Ceiling, Electrical and HVAC Work at Hostel C&D Block and Miscellaneous Work in All the Hostels of HNLU.**

This is to inform all concerned bidders that an inadvertent error has been noticed in the tender document titled "**Tender Document for False Ceiling, Electrical and HVAC Work at Hostel C&D Block and Miscellaneous Work in All the Hostels of HNLU**" under Tender No. **HNLU/376/NIT/2025-26**.

In the Electrical Works section, Item S.No. 19, the specification mentioned in the tender document shall be read as under:

### **Existing Specification**

"Supplying and laying following sizes one number FRLS PVC insulated/XLPE, PVC sheathed, steel armoured, aluminium conductor power cable of 1.1 KV grade direct in ground at a depth not less than 40 cm and up to 90 cm including excavation, sand cushioning, protective covering and refilling the trench etc. as per specification, IS: 1554 (1988, Part 1)/IS: 7098 (1988, Part 1). 4 x 16 sq. mm."

### **Revised Specification**

"Item 15.13.5 – Supplying and laying following sizes one number FRLS PVC insulated sheathed, steel armoured, copper conductor control/power cable of 1.1 kV grade in existing PVC/GI pipe etc. as per specification and IS 694 (2010) – 4 x 16 sq. mm."

Accordingly, the word "**aluminium conductor**" appearing in the original specification shall be treated as "**copper conductor**" for the said item.

All other terms and conditions of the tender document shall remain unchanged.

  
**Registrar (I/c)**

### **Copy to:**

1. Office of the Hon'ble Vice Chancellor,
2. Office of the Registrar,
3. Engineering Section,
4. File Copy.